

This document has been translated for informative purpose only.
Original version in German. In any case of doubt the German version is valid.

EC-CERTIFICATE OF CONFORMITY

0672 - CPD - 0106

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993 and implemented in Germany through the Construction Products Law of 28 April 1998, it has been stated that the construction products

Overhead door closer
“GEZE TS 2000 NV” and “GEZE TS 2000 NV BC”
with the classification enclosed in this certificate

placed on the market by

GEZE GmbH
Reinhold-Vöster-Str. 21-29
D-71229 Leonberg

and produced in the factory

factory 02

are submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved bodies have performed the initial type-testing for the relevant characteristics of the products, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

EN 1154:1996 + A1:2002

were applied and that the products fulfil all the prescribed requirements.


This certificate was first issued on July 9th, 2007, replaced by the version of June 3rd, 2008 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.


Stuttgart, June 3rd, 2008

Materials Testing Institute – University of Stuttgart
Section Fire Resistance of Construction Components
Certification Body

Wies

(Dr. rer. nat. S. Wies)
Deputy Head of the Certification Body





Enclosure to the EC–Certificate of Conformity

0672 – CPD – 0106
Revision C ^{a)}

Classification of the door closer*

GEZE TS 2000 NV
GEZE TS 2000 NV BC

EN 1154

4	8	4 2	1	1	4
---	---	--------	---	---	---

* The assembly of this door closer can be carried out in normal, frame or parallel arm mounting.

Note: The manufacturer has to point out in the assembly and adjustment documents of the door closer, that the door closer should be at least on size 3 for use on fire/smoke door assemblies.

^{a)} This enclosure replaces the version of June 3rd, 2008 (Revision B).

Stuttgart, April 18th, 2011

Materials Testing Institute – University of Stuttgart
Section Fire Resistance of Construction Components
Certification Body

(Dr. rer. nat. S. Wies)
Deputy Head of the Certification Body





This document has been translated for informative purpose only.
Original version in German. In any case of doubt the German version is valid.

EC-CERTIFICATE OF CONFORMITY

0672 - CPD - 0118

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction products

Overhead Door Closers **“GEZE TS 2000 V” and “GEZE TS 2000 V BC”**

with the classification enclosed in this certificate

placed on the market by

GEZE GmbH
Reinhold-Vöster-Str. 21-29
D-71229 Leonberg

and produced in the factory

Factory 02

are submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved bodies have performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and perform the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

EN 1154:1996 + A1:2002

were applied and that the products fulfil all the prescribed requirements.


This certificate was first issued on January 23rd, 2006 and it remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Stuttgart, January 23rd, 2006

Materials Testing Institute – University of Stuttgart
Department of Mineral Construction Materials
Certification Body


(Akad. Dir. Dipl.-Ing. K. Zeus)
Head of the Certification Body





Enclosure to the EC–Certificate of Conformity

0672 – CPD – 0118

Revision A ^{a)}

Classification of the door closers

GEZE TS 2000 V	EN 1154	4	8	5 2	1	1	4
----------------	---------	---	---	--------	---	---	---

GEZE TS 2000 V BC	EN 1154	4	8	5 2	1	1	4
-------------------	---------	---	---	--------	---	---	---

Parallel arm mounting:

GEZE TS 2000 V GEZE TS 2000 V BC	EN 1154	3	8	4	1	1	4
-------------------------------------	---------	---	---	---	---	---	---

Note: The manufacturer has to point out in the assembly and adjustment documents of the door closer, that the door closer should be at least on size 3 for use on fire/smoke door assemblies.

^{a)} This enclosure replaces the version of January 23th, 2006.

Stuttgart, March 14th, 2012

Materials Testing Institute – University of Stuttgart
Department Fire Protection
Certification Body

Stefan Wies

(Dr. rer. nat. Stefan Wies)
Deputy Head of the Certification Body

