



This document has been translated for informative purpose only.
Original version in German. In any case of doubt the German version is valid.

EC-CERTIFICATE OF CONFORMITY

0672 - CPD - 0119

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Overhead door closer "GEZE TS 1000 C"
with the classification enclosed in this certificate

placed on the market by

GEZE GmbH
Reinhold-Vöster-Str. 21-29
D-71229 Leonberg

and produced in the factory

factory 02

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved bodies have performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

EN 1154:1996 + A1:2002

were applied and that the product fulfils all the prescribed requirements.


This certificate was first issued on January 23rd, 2006, and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Stuttgart, January 23rd, 2006

Materials Testing Institute – University of Stuttgart
Department of Mineral Construction Materials
Certification Body

(Akad. Dir. Dipl.-Ing. K. Zeus)
Head of the Certification Body





Enclosure to the EC–Certificate of Conformity

0672 – CPD – 0119

Classification of the door closers

GEZE TS 1000 C

EN 1154

4	8	3 2	1	1	4
---	---	--------	---	---	---

Note: The manufacturer has to point out in the assembly and adjustment documents of the door closer, that the door closer should be at least on size 3 for use on fire/smoke door assemblies.

Stuttgart, January 23rd, 2006

Materials Testing Institute – University of Stuttgart
Department of Mineral Construction Materials
Certification Body

(Akad. Dir. Dipl.-Ing. K. Zeus)
Head of the Certification Body

